

1. Under Section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" (hereinafter referred to as "Said Act"). The applicant (Architect, Owner, Occupier by whatever name called) shall comply with all the Fire and Life Safety measures adhering to National Building Code of India, 2016 and as amended from time to time failing which it shall be treated as violation of the Said Act.
2. It is presumed that you have completed the work adhering to the provisions under Section - 3 of the said Act.
3. Sub - Section (3) of Section 3, it is responsibility of the Owner or the Occupier as the case maybe, shall furnish to the Chief Fire Officer or nominated Officer a Certificate in prescribed form twice a year in the Month of Jan & July regarding maintains of Fire Prevention and Life Safety measure in good repair and efficient condition as specified in Sub-Section (1)
4. Under sub Section (4) of Section 3. No Person shall tamper with alter, remove or cause any injury or damage to any fire prevention and life safety equipment installed in any such building or part thereof or instigate any other person to do so.

The Fire Fighting System Provided by you in the Building Premises as per Provisional No Objection Certificate Shall be well maintained & shall be kept in good working condition at all the time. If the Fire Protection system is not maintained retrenched then this "N.O.C" will stand cancelled without any notice & you will be solely responsible to loss of life or Property if any, which may please be noted.

The Condition mentioned in the "Provisional No - Objection Certificate" will remain unchanged. The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. If any change of Activity or Transfer of Plot or any future expansion, No - Objection Certificate from this Office is essential.

As per Maharashtra Fire Prevention and Life Safety Measures Act, 2006, Section 25 - Annexure - Part III, Party has paid Fire Protection Fund Fees amounting to Rs.30,000/- (Rs. Thirty Thousand only) vide UTR No. BKIDDN188801708 dated 07/07/2018 as certified by the then Architect vide his letter.

However, Town Planning is requested to verify the total built up area and inform this Department for the Purpose of levying additional Capitation fee.



Handwritten signature
10/10/19

(P.S. Rahangdale)
Director

Maharashtra Fire Service

GOVERNMENT OF MAHARASHTRA

No.MFS/51/19/736
Tel No. 2667 7555
Fax No.2666 0287

Directorate of Maharashtra Fire Service
Maharashtra Fire Service Academy
Vidyanagri, Hans Bhugra Marg,
Santacruz (East), Mumbai -400 098
Date: 10/10/2019

M/s.Prabodhan Shikshan Prasarak Santha's,
Mane international School,
Plot Bearing S. No.29,H.No. 3,
At Kuarbanv, Tai Ratnagiri,
Dist- Ratnagiri.

Sub:- Grant of " **Final No Objection Certificate**" For your
Existing Educational Building Complex on

Survey No.29, H.No. 3, At Kuarbanv, Tai Ratnagiri, Dist- Ratnagiri.

Ref: - Provisional NOC vide No. MFS/51/18/512 dated: 27.07.18

With reference to the above, a representative of this office visited your Educational Building to the above mentioned address for inspection of Fire Fighting arrangements provided. Since the firefighting arrangements provided were found in satisfactory working conditions, this office is issuing "**Final No- Objection Certificate**" for your building having Total built up area (International School Building) admeasuring to 2956.31 Sq.mtrs.

Sr. No	Name of Building	Ground	First Floor	Second Floor	Height in Mtrs
1	International School Building	1236.11	860.10	860.10	11.40 mtrs

The Said Company has kept all marginal spaces free form the obstruction as per NBC Part IV and the Fire Fighting system is installed by the license agency M/s. Hi-Tech Safety Engineers (MFS-LA/RD - 0182) & (MFS-LA/RF - 0218) has submitted certificate in "Form A" prescribe in Maharashtra Fire Prevention & Life Safety Measure Rules 2009.

The Said Company has provided (Yard Hydrant , Fire Pump , Fire Sprinkler System, Fire Alarm & Smoke Detector MCB , Hooter & Fire Pump 1280 LPM Main Pump for Sprinkler & Hydrant & Booster pump 450LPM) Now the Said company has requested to issue " Final No Objection Certificate" Statutory Provisions under Maharashtra Fire Prevention & Life Safety Measure ACT 2006".

Ward
10/10/19

